

## ADDENDUM #2



## CONTRA COSTA COMMUNITY COLLEGE DISTRICT

### D-1229 Student Union Building Gender Inclusive Restrooms

Date: April 19, 2024

---

#### NOTICE TO ALL CONTRACTORS

You are hereby notified of the following changes, clarifications and/or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and/or previous Addenda. This Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same, and shall take precedence over anything to the contrary therein. All other conditions remain unchanged.

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated **April 5, 2024**. Acknowledge receipt of this Addendum in space provided on the Bid Proposal Form. Failure to acknowledge may subject Bidder to disqualification.

---

#### DELETIONS, ADDITIONS, CHANGES, REVISIONS

##### A. Questions and Answers:

1. When is the anticipated start date of the project.
  - a. Refer to spec section 00600.
2. Duration of the project (how many days)?
  - a. Refer to spec section 00600.
3. In the general scope mentioned to electrical or fire alarm work but in page A1.10 mention to relocate the E fire alarm strobe, please confirm this is in scope or not?
  - a. Yes, relocating the (E) fire alarm strobes, so the strobe lenses are 82" AFF, is in the scope. Reference the plan notes on 2/A1.10 and 3/A1.10.
4. In page A1.10 details 2 mentioned for N door panel with vision glazing referred to note 3 as an Alternate 2, also same page detail 3 mentioned for N door panel with vision glazing referred to note 4. Would you please confirm new door, panel and hardware are part of main scope or Alternate 2?

## ADDENDUM #2

- a. Base scope is (N) door panel with vision glazing, reinstalled with salvaged (E) hardware. Alternate 2 is (N) door panel with vision glazing, frame, and hardware. Per the notes, Alt. 2 is if re-installation of (E) hardware is not possible due to incompatibility of the (E) hardware and the (N) door panel.

**B.** If you have any questions regarding this Addendum, please contact:

**Ben Cayabyab**  
**Contra Costa Community College District**  
**500 Court St., Martinez, CA 94553**  
**Email:** bcayabyab@4cd.edu  
**Phone:** 925-229-6956

All other terms and conditions of this BID are to remain the same.



---

Ben Cayabyab  
Contracts Manager

**END OF ADDENDUM #1**