


Governing Board

Andy Li
Judy E. Walters, Ph.D.
Fernando Sandoval
John E. Márquez
Rebecca Barrett

President
Vice President
Secretary



Chancellor
Bryan Reece, Ph.D.

College Presidents
Tia Robinson-Cooper, Ed.D. Contra Costa College
Susan E. Lamb Diablo Valley College
Robert Kratochvil, Ed.D. Los Medanos College

Contra Costa Community College District
San Ramon Valley College
Boiler Replacement Invitation to Quote (Informal)
ADDENDUM NO. 2

Question and Answer:

1. **Question:** Can you tell me if there are any DDC controls at this site, does the new boiler require BACnet controls?

Answer: Yes, there are DDC control at the site. Yes, the new Boiler require the ability to be connected the BACnet controls.

2. **Question:** Please reconsider C 20 license as adequate.

Answer: We are requiring a C-4 license.

3. **Question:** In looking to start filling out bid bond paperwork I realized that there don't appear to be any specs available with the documents on the district website. Could you please assist me in gaining access to these?

Answer: Specs for the unit were supplied on the tag. Please see addendum 1.

4. **Question:** We also have a C-36 License. State of CA allows C 36 to install boilers as long as C-4 applies for permit to operate. (Would C-36 license suffice?)

Answer: The installer has to have a C-4 license. The installer/vendor can bring in an Aerco tech to do the start up to ensure the warranty is valid but they will have to show proof that the tech is Aerlco certified or provide proof that they, the installer, is Aerco certified to ensure warranty is valid.

All other facts and specifications to this bid remain unchanged. **Please acknowledge receipt of this addendum number 2 by signing and submitting this page with your bid.**

Signature _____ Date _____

Rod Herrera
Senior Buyer
CCCCD