

## ADDENDUM #3



### CONTRA COSTA COMMUNITY COLLEGE DISTRICT CONTRA COSTA COLLEGE C-1067 AA BUILDING CHILLER RETORIFT PLUS PUMPING VFDS

Date: August 25 2016

---

#### NOTICE TO ALL CONTRACTORS:

You are hereby notified of the following changes, clarifications and/or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and/or previous Addenda. This Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same, and shall take precedence over anything to the contrary therein. All other conditions remain unchanged.

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated **July 29, 2016**. Acknowledge receipt of this Addendum in space provided on the Bid Proposal Form. Failure to acknowledge may subject Bidder to disqualification.

---

#### MODIFICATIONS TO CONTRACT DOCUMENTS:

- 1) Pre-bid RFIs
  - a) **Question:** After reviewing the specs and the mechanical drawings there seems to be a discrepancy. The mechanical drawings show both Reliable Controls and ALC as existing onsite controls but the specs clearly state the system is ALC and the new system will be ALC no exceptions permitted.

Please clarify what BMS/DDC controls should use in this project. Also, does Contra Costa District has any preference on controls vendors?.

**Response:** The current chiller is controlled by a Reliable control system. The existing Reliable system shall be disconnected and demolished. The new control system shall be ALC.

### **ADDENDUM #3**

If you have any questions regarding this Addendum, please contact:

**Jovan Esprit, Contract Manager**  
**Contra Costa Community College District**  
**500 Court St., Martinez, CA 94553**  
**Email: [jesprit@4cd.edu](mailto:jesprit@4cd.edu)**

All other terms and conditions of BID are to remain the same.

**END OF ADDENDUM #3**