

ADDENDUM # 3



CONTRA COSTA COMMUNITY COLLEGE

D-4021 Gas Valves and Gas Line Replacement
Diablo Valley College

Date: March 8, 2018

NOTICE TO ALL CONTRACTORS

You are hereby notified of the following changes, clarifications and/or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and/or previous Addenda. This Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same, and shall take precedence over anything to the contrary therein. All other conditions remain unchanged.

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents dated **February 2018**. Acknowledge receipt of this Addendum in space provided on the Bid Proposal Form. Failure to acknowledge may subject Bidder to disqualification.

A. Clarifications

1. QUESTION: My question is about the procedures and qualifications used to connect new 6" gas piping as well as the various new gas valve installations for the DVC D-4021 Gas Valves and Gas Line Replacement project. We follow PG&E standards when fusing/welding PE pipes of all sizes, will these procedures be followed for the new 6" gas line as well as the new Poly gas valves? These include PG&E GAS-0160, GAS-2160 and GAS-2161 training. The certifications required for various jobs that we perform for PE pipe installation include PGE21-06 for Mechanical Heat Iron Butt Fusion, PGE21-07 for Hydraulic Heat Iron Butt Fusion, PGE21-08 for safely electrofusing PE natural gas piping together with Electrofusion couplings, and PGE21-09 for safely electrofusing an electrofusion saddle onto PE natural gas pipe. These procedures and certifications are followed to ensure PE fusing/welding is performed safely and to ensure the long-term stability of the natural gas system in place.

RESPONSE: The contractor has the option to install the gas system and components per PG&E standards and procedures. However, at a minimum, contractor to install the new gas installations following the contract specification section 23 11 23.

ADDENDUM # 3

B. If you have any questions regarding this Addendum, please contact:

Jovan Esprit, Contracts Manager
Contra Costa Community College District
500 Court St., Martinez, CA 94553
Email: jesprit@4cd.edu ;
Facsimile: 925-370-7512;

All other terms and conditions of BID are to remain the same.

END OF ADDENDUM # 3